

# KITA SP/R290

MODELLO	Riscaldamento												Sanitaria		Raffreddamento			
	A 12°C / W 35° C		A 7°C / W 35° C		A 2°C / W 35° C		A -7°C / W 35° C		A -15°C / W 35° C		A -20°C / W 35° C		A 2°C / W 65° C		A 35°C / W 7° C		A 35°C / W 18° C	
	Qh	COP	Qh	COP	Qh	COP	Qh	COP	Qh	COP	Qh	COP	Qh	COP	Qc	EER	Qc	EER
	kW		kW		kW		kW		kW		kW		kW		kW		kW	
SP-8	9,20	6,11	8,19	5,26	7,00	4,59	5,20	3,62	4,10	2,89	3,40	2,46	5,90	2,02	6,99	3,48	9,66	4,70
SP-10	11,40	6,02	10,00	5,16	8,80	4,45	6,80	3,47	5,30	2,76	4,40	2,37	7,40	2,06	8,02	3,42	11,00	4,55
SP-12	14,30	5,94	12,50	5,06	10,60	4,37	8,00	3,37	6,20	2,67	5,20	2,29	10,90	2,05	9,04	3,36	12,32	4,38