

KITA LP/R290

MODELLO	Riscaldamento											Sanitaria		Raffreddamento				
	A 12°C / W 35° C		A 7°C / W 35° C		A 2°C / W 35° C		A -7°C / W 35° C		A -15°C / W 35° C		A -20°C / W 35° C		A 2°C / W 65° C		A 35°C / W 7° C		A 35°C / W 18° C	
	Qh	COP	Qh	COP	Qh	COP	Qh	COP	Qh	COP	Qh	COP	Qh	COP	Qc	EER	Qc	EER
	kW		kW		kW		kW		kW		kW		kW		kW		kW	
LP-22 4.1.9.2	24,90	5,72	22,20	4,98	19,60	4,37	15,60	3,49	12,40	2,87	10,60	2,53	18,24	2,8	14,45	3,43	20,13	4,61
LP-26 4.1.9.1	29,70	6,15	26,20	5,30	25,20	4,49	22,60	3,40	18,00	2,80	15,60	2,52	19,92	1,89	20,85	2,57	27,97	3,18
LP-28 4.1.10.1	32,30	6,06	28,30	5,20	25,10	4,45	19,80	3,41	15,50	2,76	13,30	2,46	23,00	2,22	17,43	2,91	23,66	3,63
LP-32 4.1.10.2	36,30	5,62	32,20	4,90	28,30	4,29	22,20	3,43	17,80	2,87	15,50	2,59	26,30	2,22	19,01	2,73	25,60	3,38
LP-35 4.1.10.3	39,70	5,47	35,10	4,79	30,90	4,21	24,20	3,37	19,30	2,81	16,70	2,55	19,60	2,26	20,58	2,54	27,54	3,12